




REVISIONS			
ZONE LTR	DESCRIPTION	DATE	APPROVED

ASSEMBLE THE RACK TO THE DUST COVER USING THE FOLLOWING:
 #1/2-13 X 1-1/2" L.G. (GRD. #5) BOLT (4X)
 #1/2 FLATWASHER (4X)
 #1/2 LOCKWASHER (4X)
 #1/2-13 (GRD. #5) HEX NUT (4X)



NOTES:
 FINISH-EPOXY POWDER, ASA 61 GREY
 WELDED CONSTRUCTION

THIS DOCUMENT CONTAINS PROPRIETARY DATA OF SMTI AND JCI. NO DISCLOSURE, REPRODUCTION OR USE OF ANY PART THEREOF MAY BE MADE WITHOUT WRITTEN PERMISSION. THIS IS A CAD GENERATED DRAWING. NO MANUAL CHANGES ALLOWED.

BILL OF MATERIALS			
QTY	ITEM	PART NUMBER	DESCRIPTION
1	3	CROSSMEMBER	10 GA HR P&D
2	2	UPRIGHT	3" X 4.30L.B. HR C-CHANNEL
2	1	SUPPORT	6" X 3-1/2" X 3/8" HR ANGLE

UNLESS OTHERWISE SPECIFIED		CONTR.	JOHNSON CONTROLS, INC.
DIMENSIONS ARE IN INCHES		DRAWN	SPECIALTY BATTERY
TOLERANCES UNLESS OTHERWISE SPECIFIED		CHKD	RELAY RACK, MODULAR RACK
FRACTIONS TO 1/16"		APPROVED	SYSTEM-ZONE 4 / RACK A
DECIMALS TO 0.005"		APPROVED	SIZE C CODE IDENT NO. DRAWING NO.
HOLE DIMENSIONS TO 0.002"		DESIGN ACT APPVL	MRR4-7050
HOLE LOCATIONS TO 0.005"		CONTR. ACT APPVL	SCALE: NONE
MATERIAL:			SHEET 1 OF 1
FINISH:			
AS NOTED			
NEXT ASSY USED ON			
APPLICATION			