



REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED



NOTES:
 FINISH-EPOXY POWDER, ASA 61 GREY

ASSEMBLY IS QUALIFIED AND CERTIFIED FOR UBC SEISMIC ZONE 4

THIS DOCUMENT CONTAINS PROPRIETARY DATA OF SHI AND JCI. NO DISCLOSURE, REPRODUCTION OR USE OF ANY PART THEREOF MAY BE MADE WITHOUT WRITTEN PERMISSION. THIS IS A CAD GENERATED DRAWING. NO MANUAL CHANGES ALLOWED.

BILL OF MATERIALS			
QTY	ITEM	PART NUMBER	DESCRIPTION
1	4	MRR4-3525	RACK "H"
1	3	MRDC-105	DUST COVER
3	2	MRT-105	Z-4 RELAY RACK-FIXED SHELF/TIER
1	1	MRB-105	Z-4 RELAY RACK-FIXED SHELF/BASE

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	CONTR.	JOHNSON CONTROLS, INC.		
TOLERANCES FRACTIONS DECIMALS	DRAWN RVG 5/28/97	SPECIALTY BATTERY		
HOLE ± .010	CHECKED	(TEL12-105) Z-4 MODULAR		
1 PLACE DECIMALS ± .005	APPROVED	SINGLE BAY SYSTEM - 4 TIER		
2 PLACE DECIMALS ± .001	APPROVED	W/RELAY RACK		
MATERIAL:	DESIGN ACT APPVL	SIZE	CODE IDENT NO.	DRAWING NO.
		D		SBMF-4TR
NEXT ASSY	USED ON	FINISH:	GOVT ACT APPVL	REV.
				-
APPLICATION			SCALE:	SHEET 1 OF 1