REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED







NOTES:
FINISH-EPOXY POWDER, ASA 61 GREY

ASSEMBLY IS QUALIFIED AND
CERTIFIED FOR UBC SEISMIC ZONE 4

THIS DOCUMENT CONTAINS PROPRIETARY DATA OF SMFT AND JCI. NO DISCLOSURE, REPRODUCTION, OR USE OF ANY PART THEREOF MAY BE MADE WITHOUT WRITTEN PERMISSION. THIS IS A CAD GENERATED DRAWING. NO MANUAL CHANGES ALLOWED.

BILL OF MATERIALS

QTY	ITEM	PART NUMBER	DESCRIPTION
1	3	MRDC-105	DUST COVER
5	2	MRT-105	Z-4 RELAY RACK-FIXED SHELF,TIER
1	1	MRB-105	Z-4 RELAY RACK-FIXED SHELF,BASE

CONTR.	JOHNSON CONTROLS, INC. SPECIALTY BATTERY
DRAWN RVG 5/28/97	
CHECKED	(TEL12-105) Z-4 MODULAR SINGLE BAY SYSTEM - 6 TIER
APPROVED	
APPROVED	
DSGN ACT APPVL	SIZE: D; CODE IDENT NO.; DRAWING NO.: SBMF-6T; REV.: -
GOVT ACT APPVL	SCALE:; SHEET 1 OF 1

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES (FRACTIONS AND/OR ANGLES) ± 1 DEG. 2 PLACE DECIMALS ± .010 3 PLACE DECIMALS ± .005

MATERIAL:

FINISH:

NEXT ASS'Y | USED ON

APPLICATION