REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED

DUST COVER
REMOVED FOR CLARITY





② SCREW DRAWER TO FRAME USING #3/8-16 BOLTS (GRD. 5) X 1" LG. WITH A #3/8" LOCKWASHER AND A #3/8" FLATWASHER (4X PER SHELF)

① ASSEMBLE THE DUST COVER USING THE FOLLOWING HARDWARE:
#3/8-16 X 1"LG. (GRD.#5) CARRIAGE BOLT (10X)
#3/8 FLATWASHER (10X)
#3/8 LOCKWASHER (8X)
#3/8 "SHAKEPROOF" WASHER (2X)(REAR HOLES)
#3/8-16 (GRD.#5) HEX NUT (10X)



NOTES:
FINISH-EPOXY POWDER, ASA 61 GREY

ASSEMBLY IS QUALIFIED AND CERTIFIED FOR UBC SEISMIC ZONE 4

COVER INCLUDES RELAY RACK MOUNTING HOLES

THE RACK IS WELDED CONSTRUCTION

THIS DOCUMENT CONTAINS PROPRIETARY DATA OF SAFT AMB JCI. NO DISCLOSURE, REPRODUCTION, OR USE OF ANY PART THEREOF MAY BE MADE WITHOUT WRITTEN PERMISSION. THIS IS A CAB GENERATED DRAWING. NO MANUAL CHANGES ALLOWED.

BILL OF MATERIALS

QTY	ITEM	PART NUMBER	DESCRIPTION
1	4	MRR4-6875	RACK "B"
4	3	MHD125-180	BATTERY HOLDDOWN (NOT SHOWN)
1	2	MRDC-LHD	DUST COVER, HEAVY DUTY
1	1	MRB-L	Z-4 SLIDING BATTERY SHELF-BASE

CONTR.	JOHNSON CONTROLS, INC. SPECIALTY BATTERY
DRAWN RMS 6/18/97	(TEL12-125/6-180)Z-4 MODULAR SINGLE BAY SYSTEM - 1 TIER W/RELAY RACK
CHECKED	
APPROVED	
APPROVED	
DSGN ACT APPVL	SIZE D · CODE IDENT NO. · DRAWING NO. SBML-1TR · REV. -
GOVT ACT APPVL	SCALE: · SHEET 1 OF 1

MATERIAL:
FINISH:
NEXT ASSY | USED ON
APPLICATION