DUST COVER
REMOVED FOR CLARITY





③ SCREW DRAWER TO FRAME USING #3/8-16 BOLTS (GRD. 5) X 1" LG. WITH A #3/8" LOCKWASHER AND A #3/8" FLATWASHER (4X PER SHELF)

② ASSEMBLE SHELVES AND DUST COVER USING THE FOLLOWING HARDWARE PER SHELF:
#3/8-16 X 1"LG. (GRD.#5) CARRIAGE BOLT (10X)
#3/8 FLATWASHER (10X)
#3/8 LOCKWASHER (8X)
#3/8 "SHAKEPROOF" WASHER (2X)(REAR HOLES)
#3/8-16 (GRD.#5) HEX NUT (10X)

① ASSEMBLE THE RACK TO THE DUST COVER USING THE FOLLOWING:
#1/2-13 X 1-1/2" LG. (GRD. #5) BOLT (4X)
#1/2 FLATWASHER (4X)
#1/2 LOCKWASHER (4X)
#1/2-13 (GRD. #5) HEX NUT (4X)



REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED

NOTES:
FINISH-EPOXY POWDER, ASA 61 GREY

ASSEMBLY IS QUALIFIED AND CERTIFIED FOR UBC SEISMIC ZONE 4

COVER INCLUDES RELAY RACK MOUNTING HOLES

THE RACK IS WELDED CONSTRUCTION

THIS DOCUMENT CONTAINS PROPRIETARY DATA OF SWFT AND JCI. NO DISCLOSURE, REPRODUCTION OR USE OF ANY PART THEREOF MAY BE MADE WITHOUT WRITTEN PERMISSION. THIS IS A CAD GENERATED DRAWING. NO MANUAL CHANGES ALLOWED.

BILL OF MATERIALS

QTY	ITEM	PART NUMBER	DESCRIPTION
1	5	MRR4-4175	RACK "G"
12	4	MH0125-180	BATTERY HOLDDOWN (NOT SHOWN)
1	3	MRDC-LHD	DUST COVER, HEAVY DUTY
2	2	MRT-L	Z-4 SLIDING BATTERY SHELF-TIER
1	1	MRB-L	Z-4 SLIDING BATTERY SHELF-BASE

CONTR	JOHNSON CONTROLS, INC. SPECIALTY BATTERY
DRAWN RVG 6/18/97	(TEL12-125/6-180)Z-4 MODULAR SINGLE BAY SYSTEM - 3 TIER W/RELAY RACK
CHECKED	
APPROVED	
APPROVED	
DSGN ACT APPVL	SIZE R · CODE IDENT NO. · DRAWING NO. · REV.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES
TOLERANCES DECIMALS ANGLES ± 1 DEG.
2 PLACE DECIMALS ± .03
3 PLACE DECIMALS ± .010
MATERIAL: