



DUST COVER
REMOVED FOR CLARITY




REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED



③
SCREW DRAWER TO
FRAME USING #3/8-16
BOLTS (GRD. 5) X 1" LG.
WITH A #3/8" LOCKWASHER
AND A #3/8" FLATWASHER
(4X PER SHELF)

②
ASSEMBLE SHELVES AND DUST COVER
USING THE FOLLOWING HARDWARE PER SHELF:
#3/8-16 X 1" LG. (GRD.#5) CARRIAGE BOLT (10X)
#3/8 FLATWASHER (10X)
#3/8 LOCKWASHER (8X)
#3/8 "SHAKEPROOF" WASHER (2X)(REAR HOLES)
#3/8-16 (GRD.#5) HEX NUT (10X)



NOTES:
FINISH-EPOXY POWDER, ASA 61 GREY
ASSEMBLY IS QUALIFIED AND
CERTIFIED FOR UBC SEISMIC ZONE 4
COVER INCLUDES RELAY RACK MOUNTING
HOLES
▪ BATTERY HOLDDOWNS AS REQ.

THIS DOCUMENT CONTAINS PROPRIETARY DATA
OF EMC AND JCL. NO DISCLOSURE, REPRODUCTION,
OR USE OF ANY PART THEREOF MAY BE MADE
WITHOUT WRITTEN PERMISSION. THIS IS A CAD
GENERATED DRAWING. NO MANUAL CHANGES
ALLOWED.

BILL OF MATERIALS			
QTY	ITEM	PART NUMBER	DESCRIPTION
24	5	MHD70-90	BATTERY HOLDDOWN (NOT SHOWN)
12	4	MHD30-45	BATTERY HOLDDOWN (NOT SHOWN)
1	3	MRDC-S	DUST COVER
5	2	MRT-S	Z-4 SLIDING BATTERY SHELF-TIER
1	1	MRB-S	Z-4 SLIDING BATTERY SHELF-BASE

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES UNLESS OTHERWISE SPECIFIED ARE: FRACTIONS > 1/16" ± 0.005 1 PLACE DECIMALS ± 0.010 2 PLACE DECIMALS ± 0.005	CONTR. DRAWN: RYG 6/18/97 CHECKED: APPROVED: DSGN ACT APPVL: CONVT ACT APPVL:	JOHNSON CONTROLS, INC. SPECIALTY BATTERY (TEL12-30/12-90) Z-4 MODULAR SINGLE BAY SYSTEM - 6 TIER	SIZE: D CODE IDENT NO.: DRAWING NO.: SBMS-6T REV.: -
NEXT ASSY: USED ON: APPLICATION:	MATERIAL: AS NOTED FINISH: AS NOTED	SCALE:	SHEET 1 OF 1